



Procontrol P14

89AS30R0100

Module and Application Description
Analog Signal Multiplier

Power and productivity
for a better world™

ABB

Procontrol P14

89AS30R0100

Analog Signal Multiplier

NOTICE

This document contains information about one or more ABB products and may include a description of or a reference to one or more standards that may be generally relevant to the ABB products. The presence of any such description of a standard or reference to a standard is not a representation that all of the ABB products referenced in this document support all of the features of the described or referenced standard. In order to determine the specific features supported by a particular ABB product, the reader should consult the product specifications for the particular ABB product.

ABB may have one or more patents or pending patent applications protecting the intellectual property in the ABB products described in this document.

The information in this document is subject to change without notice and should not be construed as a commitment by ABB. ABB assumes no responsibility for any errors that may appear in this document.

In no event shall ABB be liable for direct, indirect, special, incidental or consequential damages of any nature or kind arising from the use of this document, nor shall ABB be liable for incidental or consequential damages arising from use of any software or hardware described in this document.

This document and parts thereof must not be reproduced or copied without written permission from ABB, and the contents thereof must not be imparted to a third party nor used for any unauthorized purpose.

The software or hardware described in this document is furnished under a license and may be used, copied, or disclosed only in accordance with the terms of such license. This product meets the requirements specified in EMC Directive 2014/30/EC.

TRADEMARKS

Procontrol is a registered trademark of ABB AG.

All rights to copyrights, registered trademarks, and trademarks reside with their respective owners.

Copyright © 2016 ABB.

All rights reserved.

Release: July 2016

Document number: 2VAA008052

TABLE OF CONTENTS

1. APPLICATION	6
2. FEATURES	6
3. DESCRIPTION	6
4. ANNUNCIATION FUNCTION	6
5. FUNCTION DIAGRAM.....	7
6. SETTINGS.....	8
7. CONNECTION DIAGRAM	9
8. MODULE DESIGN	10
9. SYSTEM DATA.....	12
10. TECHNICAL DATA.....	12
10.1 Power supply	12
10.2 Process Interface.....	12
10.2.1 Input values E1, E2, E3.....	12
10.2.2 Transmitter supply US1, US2, US3.....	12
10.2.3 Output values	12
10.2.4 Transmission values	13
10.3 Interference immunity (of process inputs and outputs)	13
11. ORDERING DATA	13
11. REVISION HISTORY	14

1. APPLICATION

This module is used for converting and multiplying analog signals.

2. FEATURES

The module is designed to process input signals of a level of 0 ... 20 mA or 4 ... 20 mA or 0 ... 10 V DC, the ranges being selected by means of jumpers. From the input signal, three output signals of 0 ... 20 mA or 4 ... 20 mA are formed which can be selected individually by using jumpers; also a signal of 0 ... 10 V is formed.

3. DESCRIPTION


The inputs are electrically isolated from the rest of the circuitry. For supplying transmitters and other devices, a voltage of 15 V or 24 V DC is available for each input, also electrically isolated.

The module contains three identical function units. The outputs are separated.

4. ANNUNCIATION FUNCTION

A green light-emitting diode on the front panel indicates when the module is ready for operation.

5. FUNCTION DIAGRAM



6. SETTINGS

Type of input signals and output signals desired, and transmitter supply need to be selected by means of jumpers (JPxx).

Inputs

FE1 E1	JP10	JP11	JP12
FE2 E2	JP20	JP21	JP22
FE3 E3	JP30	JP31	JP32
	I U	I U	I U
0 ... 20 mA	○—○	○—○	○—○
4 ... 20 mA	○—○	○—○	○—○
0...10 V	○—○	○—○	○—○

Transmitter supply

US1	JP19
US2	JP29
US3	JP39
	24 V 15 V
15 V	○—○
24 V	○—○

Outputs


FE1 A11	JP13	JP14
FE2 A21	JP23	JP24
FE3 A31	JP33	JP34
	4 mA 0 mA	4 mA 0 mA
0 ... 20 mA	○—○	○—○
4 ... 20 mA	○—○	○—○

FE1 A12	JP15	JP16
FE2 A22	JP25	JP26
FE3 A32	JP33	JP36
	4 mA 0 mA	4 mA 0 mA
0 ... 20 mA	○—○	○—○
4 ... 20 mA	○—○	○—○


FE1 A13	JP17	JP18
FE2 A23	JP27	JP28
FE3 A33	JP37	JP38
	4 mA 0 mA	4 mA 0 mA
0 ... 20 mA	○—○	○—○
4 ... 20 mA	○—○	○—○

7. CONNECTION DIAGRAM

Connection of externally supplied signal sources




Connection of twin – core transducers



Connection of four-core transducers

Possible only if their current consumption < 25 mA



8. MODULE DESIGN


- Board size: 3 units, 1 division, 160 mm deep
- Connector: to DIN 41 612 / IEC 60603-2
1 x 48-pole edge connector, type F
- Weight: approx. 0.3 kg

Contact assignments of connector X1

View of contact side:

	<i>d</i>	<i>b</i>	<i>z</i>
02	E3+	E2+	E1+
04	E3-	E2-	E1-
06	US3+	US2+	US1+
08	Z3	Z2	Z1
10			
12	A31+	A21+	A11+
14	A31-	A21-	A11-
16	A32+	A22+	A12+
18	A32-	A22-	A12-
20	A33+	A23+	A13+
22	A33-	A23-	A13-
24	A34+	A24+	A14+
26	A34-	A24-	A14-
28			
30	Z	Z	Z
32	USA	USA	USB

Side view with jumper positions and view of module front



9. SYSTEM DATA

Kind of influence	Environmental Parameter	Standard	Characteristic/Value
Operating conditions			
Climatic environment	Ambient temperature	IEC/EN 60068-2-2	0°C to +70°C, 16h
	Relative humidity	IEC/EN 60068-2-78	5% to 95% RH
	Atmospheric pressure	IEC/EN 60068-1	86 kPa to 106 kPa
Electromagnetic compatibility (EMC)	Electrostatic discharge immunity	IEC/EN 61000-4-2 Class 3 Class 2	Air discharge 8 kV Contact discharge 4 kV
	Radiated, radio-frequency, electromagnetic field immunity	IEC/EN 61000-4-3 Class 3	80 MHz to 3000 MHz, 10 V/m, 80 % AM (1 kHz)
	Electrical fast transient/burst immunity - Supply lines for AC 120/230 V (burst) - Supply lines for DC 24 V - Signal lines (I/O and bus lines)	IEC/EN 61000-4-4 Class 3	5/50 ns 2 kV 2 kV 2 kV
	Surge immunity - Supply lines for AC 120/230 V (burst) - Supply lines for DC 24 V - Signal lines (I/O and bus lines)	IEC/EN 61000-4-5 Class 4/3 Class 1/1 Class 3	1.2/50 ns 4/2 kV 0.5/0.5 kV 2 kV
	Immunity to conducted disturbances, induced by radio-frequency fields	IEC/EN 61000-4-6 Class 3	0.15 MHz to 80 MHz, 10 V, 80% AM (1 kHz), Source impedance 150 Ω
	Radiated emission	CISPR16 / EN 55016 Class A	30 MHz to 1000 MHz, Limit Class A, group 1
Conditions of storage and transport			
Climatic environment	Ambient temperature	IEC/EN 60068-2-2	-40°C to +85°C, 16h
	Relative humidity	IEC/EN 60068-2-30	5% to 100% RH +25°C to 40°C (6 cycles)
	Atmospheric pressure	IEC/EN 60068-1	70 kPa to 106 kPa

10. TECHNICAL DATA

10.1 Power supply

Supply voltage	+24 V DC
Current consumption	approx. 110 mA + output currents

10.2 Process Interface

10.2.1 Input values E1, E2, E3

Voltage input	0 ... 10 V (max. 30 V)
Input resistance	> 100 kOhm
Current input	0 ... 20 mA, 4 ... 20 mA
Load resistance RB	55 Ohm

10.2.2 Transmitter supply US1, US2, US3

Selectable by means of jumpers	15 V DC, max. 25 mA 24 V DC, max. 25 mA
--------------------------------	--

10.2.3 Output values

Current outputs A11, A12, A13, A21, A22, A23, A31, A32, A33 Selectable by means of jumpers	0 ... 20 mA 4 ... 20 mA
---	----------------------------

ORDERING DATA

Interference immunity (of process inputs and outputs)

Max. burden RB	1000 Ohm
Voltage outputs A14, A24, A34 Max. current	0 ... 10 V (max. 12 V) 5 mA

10.2.4 Transmission values

Transmission error at input/output within the permissible temperature range and the permissible Supply voltage tolerances	$\leq 0.3 \%$
Signal delay	< 1 msec

10.3 Interference immunity (of process inputs and outputs)

The product is in conformity with the provisions of the following European Directive:

2014/30/EC Directive of the European Parliament and of the Council of 26 Februar 2014 on the harmonization of the laws of member States relating to electromagnetic compatibility (EMC Directive)

Conformity to the stated Directive is assured through the application of the following harmonized standards:

Environment: Industry
EMC, Emission: EN 61000-6-4: 2007/A1:2011
EMC, Immunity: EN 61000-6-2: 2005/AC:2005

See 2VAA002182R0301_CE-Conformity-P14.pdf for detailed technical data.

11. ORDERING DATA

Order no. for complete module:

Type designation: 89AS30R0100 Order number: GKWN000317R0100

Technical data are subject to change without notice!

11. REVISION HISTORY

Rev.		Date / Initial
1.0	Replaces D KWL 6348 94 E	2016-06-29 CG

ABB Inc.
Power Generation
Wickliffe, Ohio, USA
E-Mail: powergeneration@us.abb.com
www.abb.com/controlsystes

ABB AG
Power Generation
Mannheim, Germany
E-Mail: powergeneration@de.abb.com
www.abb.com/controlsystes

ABB Pte. Ltd.
Power Generation
Singapore
E-Mail: powergeneration@sg.abb.com
www.abb.com/controlsystes